



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH
OFFICE OF THE DIRECTOR FIRE AND RESCUE SERVICES UT LADAKH

(e-mail-soto-igp@police.ladakh.gov.in)

(Office Phone Number.01982-260888)

Number: - F&RS/Dir/NOC/2025- 12407-408

Dated: - 18/07/2025

Subject: Fire NOC of Govt. High School Thiksay, Leh.

The report has been submitted by Deputy Director, Ladakh regarding the inspection of the instant School building wherein the spot visit has been conducted by DFO Fire and Rescue Services Station, Leh. The detailed report of the school building is as under:

Location/ Accessibility:

The school building is constructed at Thiksay, Leh. It is located at latitude 34.043329 and longitude 77.672136. The site is approximately 19 Kms away from Fire and Rescue Service Station Leh, it takes 30 minutes to reach the site and is approachable for fire appliances.

Detail of building:

The school has plot area about 3541.006 sq.mtrs while as plinth area is about 177.0503 sq. mtrs. As per code 3.1.2 of the NBC 2016 the building falls under Group "B" Educational Buildings. Subdivision B-1 School up to senior secondary level. The height of the school 1st block is 6.9 meters and 2nd, 3rd, 4th, 5th, 6th and 7th are 3.6 meters.

The school building has 07 blocks and the detail of the block are as under:

1st block: It is two stored building having one stair case. In the ground floor there are computer room and classroom. There is one window each room and the size are 6x5 feet. 1st floor has headmaster office.

2nd block: It is single stored building having mid-day meal. There are two windows and the size is 5x4 feet. Two side of window have provision to open.

3rd block: It is single stored building having smart class, staff room, science laboratory, library, store kitchen and 6 number of class rooms. There are two windows in each room and the size is 3x4 feet. Two side of window have provision to open.

4th block: It is single stored building having 06 number of class rooms. There are three windows in each class room and the size is 3x4 feet. Two side of the window have provision to open.

5th block: It is single stored building having smart class room and ICDS and one room. There is room one window in each room and the size is 3x5 feet. Two side of the window have provision to open.

6th block: It is single stored building having sport room and 2 number of stores. There are two windows in each room and the size is 6x4 feet. Two side of the window have provision to open.

7th block: It is single storied building having solar bank.


There are 196 students and 22 staffs. Accordingly, the following Minium firefighting installation are required and applied.

The following Fire Safety equipment are installed in school Building:

1. 08 number of fire extinguisher ABC Type 4 kg capacity is installed in the school building.
2. 08 number of sand bucket is installed in the school premises.
3. 05number of plastic water tank 500 liters capacity overhead of the building.
4. 01 submersible bore connected with high rated pump is installed in the school premises.
5. 20 thousand liters underground reserve water tank shall be made in the school premises.

As per the field report, the above equipment were found to be in place. **FIRE NOC** is given in the favour of **Govt.**

High School Thiksay, Leh for period of **One year** from the issuance.


DIRECTOR
Director,
FIRE & RESCUE SERVICE
Fire and Rescue Service,
UT Ladakh.

Copy to:

1. Headmaster, Govt. High School Thiksay, Leh for information and n/a.
2. Deputy Director, F&RS, Ladakh for information.
3. Office file.